

Grand Prairie Bayou Two PWA

2023 Annual Drinking Water Quality Report

Bayou Two Water System, Grand Prairie Water System and Combined Systems

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand, and be involved in, the efforts we make to continually improve the water treatment process and protect our water resources.

Where Does Our Drinking Water Come From?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. We pump water from six Alluvial Aquifer wells and two Sparta Sand aquifer wells. We also purchase treated water from Jacksonville Water Works whose sources are twelve wells that pump from the Quaternary System Aquifer. Jacksonville Water Works also purchases water from Central Arkansas Water (CAW), which receives its supply from two surface water sources, Lake Winona and Lake Maumelle. Both lakes can supply Jackson Reservoir, a regulating reservoir located in Little Rock. Water is delivered by pipeline to the Jack H. Wilson and Ozark Point water treatment plants. Both treatment facilities are located in Little Rock. Grand Prairie Bayou Two PWA also purchases water from Lonoke-White Public Water Authority, whose source is Greer's Ferry Lake.

How Safe Is The Source Of Our Drinking Water?

The Arkansas Department of Health has completed Source Water Vulnerability Assessments for Jacksonville Water Works and Central Arkansas Water. The assessments summarize the potential for contamination of our sources of drinking water and can be used as a basis for developing source water protection plans. Based on the various criteria of the assessments, our water sources have been determined to have a low to high susceptibility to contamination. You may request summaries of the assessments from our office.

What Contaminants Can Be In Our Drinking Water?

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; Pesticides and herbicides which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; Organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to assure tap water is safe to drink, EPA has regulations which limit the number of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Unregulated Contaminant Monitoring Rule 5 (UCMR5)

Grand Prairie Bayou Two PWA participated in the fifth series of the Unregulated Contaminant Monitoring Rule (UCMR 5). The results of this monitoring will provide new data that will improve our understanding of the frequency that 29 per- and polyfluoroalkyl substances (PFAS) and lithium are found in our water, as well the nation's drinking water systems, and at what levels. The monitoring data on PFAS and lithium will help the EPA make determinations about future regulations and other actions to protect public health under the Safe Drinking Water Act (SDWA). The data will also ensure science-based decision-making, help our system and the EPA better understand whether these contaminants in drinking water disproportionately impact communities with environmental justice concerns, and allow the EPA, states, Tribes, and water systems to target solutions.

Am I at Risk?

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from small amounts of contamination. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. In addition, EPA/CDC guidelines on appropriate means to lessen the risk of infection by microbiological contaminants are also available from the Safe Drinking Water Hotline.

Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

How Can I Learn More About Our Drinking Water?

If you have any questions about this report or concerning your water utility, please contact Pam Riggin, Office Supervisor, at 501-676-2887. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Thursday of each month at 12:00 PM at Grand Prairie Bayou Two PWA Office, 11177 Arkansas Highway 31 North in Austin.

TEST RESULTS

We, Jacksonville Water Works, Central Arkansas Water (CAW) and Lonoke-White Public Water Authority routinely monitor for constituents in your drinking water according to Federal and State laws. The test results tables show the results of monitoring done by Grand Prairie Bayou Two PWA, Jacksonville and CAW for the period of January 1st to December 31st, 2022. In the tables you might find terms and abbreviations you are not familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Lithium - a chemical element of the alkali metal group that is the lightest metal known and that is used especially in alloys and glass, in mechanical lubricants, and in storage batteries.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - unenforceable public health goal; the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA - Not applicable

Parts per billion (ppb) - a unit of measurement for detected levels of contaminants in drinking water. One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) - a unit of measurement for detected levels of contaminants in drinking water. One part per million corresponds to one minute in two years or a single penny in \$10,000.

TURBIDITY						
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	Major Sources in Drinking Water
Turbidity (CAW - Ozark Point WTP)	N	Highest yearly sample result: 0.19 Lowest monthly % of samples meeting the turbidity limit: 100%	NTU	NA	Any measurement in excess of 1 NTU constitutes a violation	Soil runoff
Turbidity (CAW - Jack Wilson WTP)	N	Highest yearly sample result: 0.51 Lowest monthly % of samples meeting the turbidity limit: 99.4%				
Turbidity (Lonoke-White PWA)	N	Highest yearly sample result: 0.27 Lowest monthly % of samples meeting the turbidity limit: 100%			A value less than 95% of samples meeting the limit of 0.3 NTU, constitutes a violation	

♦ Turbidity is a measurement of the cloudiness of water. Central Arkansas Water and Lonoke-White monitors it because it is a good indicator of the effectiveness of their filtration system.

RADIOACTIVE CONTAMINANTS						
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	Major Sources in Drinking Water
Tritium (CAW)	N	5.26	pCi/L	NA	NA	Decay of natural deposits

INORGANIC CONTAMINANTS						
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	Major Sources in Drinking Water
Fluoride (Grand Prairie Bayou Two - WTP #2)	N	Average: 0.47 Range: 0.21 - 0.94	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth
Fluoride (Grand Prairie Bayou Two - WTP #3)	N	Average: 0.63 Range: 0.23 - 0.98				
Fluoride (Lonoke-White PWA)	N	Average: 0.70 Range: 0.63 - 0.90				
Fluoride (CAW-Ozark Point WTP)	N	Average: 0.77 Range: 0.72 - 0.83				
Fluoride (CAW- Jack Wilson WTP)	N	Average: 0.76 Range: 0.72 - 0.86				
Lead (Grand Prairie Bayou Two- WTP #2)	NA	Average: 2.36 Range: 0 - 5.6	ppb	0	AL=15	Erosion of natural deposits
Nitrate [as Nitrogen] (Grand Prairie Bayou Two- WTP #2)	N	Average: 1.11 Range: 1.10 - 1.12	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate [as Nitrogen] (Grand Prairie Bayou Two- WTP #3)	N	Average: 0.655 Range: 0.65 - 0.66				

LEAD AND COPPER TAP MONITORING						
Contaminants	Number of Tap Samples	Number of Sites over Action Level	90 th Percentile Result	Unit	Action Levels	Major Sources in Drinking Water
Lead (Grand Prairie Bayou Two)	30	0	<0.001	ppm	0.015	Corrosion from household plumbing systems; erosion of natural deposits
Copper (Grand Prairie Bayou Two)	30	0	0.020	ppm	1.3	
<p>♦ We are currently on a reduced monitoring schedule and required to sample once every three years for lead and copper at the customers' taps. The results above are from our last monitoring period in 2023. Our next required monitoring period is in 2026.</p>						
TOTAL ORGANIC CARBON						
<p>♦ The percentage of Total Organic Carbon (TOC) removal was routinely monitored in 2023 by our suppliers, and all TOC removal requirements set by USEPA were met. Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection by-products. These by-products include trihalomethanes (THMs) and haloacetic acids (HAAs).</p>						
REGULATED DISINFECTANTS						
Disinfectant	Violation Y/N	Level Detected	Unit	MRDLG (Public Health Goal)	MRDL (Allowable Level)	Major Sources in Drinking Water
Chlorine (Grand Prairie Bayou Two)	N	Average: 0.86 Range: 0.5 - 1.3	ppm	4	4	Water additive used to control microbes
BY-PRODUCTS OF DRINKING WATER DISINFECTION						
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	
HAA5 [Haloacetic Acids] (Grand Prairie Bayou Two)	N	0	ppb	0	60	
TTHM [Total Trihalomethanes] (Grand Prairie Bayou Two)	N	Highest Running Annual Average: 4 Range: 0 - 16.5	ppb	NA	80	
Chlorite (Central Arkansas Water)	N	Highest Annual Quarterly Average: 343 Range: 175 - 530	ppb	800	1000	
Chlorite (Lonoke-White PWA)	N	Highest Annual Quarterly Average: 391 Range: 275 - 496				
UNREGULATED CONTAMINANTS (UCMR5)						
Contaminant	Level Detected	Unit	MCLG (Public Health Goal)	Major Sources in Drinking Water		
Lithium (Grand Prairie Bayou Two)	Average: 0.0164 Range: 0.0141 - 0.0189	ppm	N/A	Naturally occurring element, present in some pharmaceuticals, sanitizing agent, batteries for electronics, food products.		

VIOLATIONS - Grand Prairie Bayou Two PWA			
TYPE: Bacteriological Monitoring	FROM:	TO:	CORRECTIVE ACTION:
Failed to take bacteriological samples in multiple sampling periods	4/1/2023	4/30/2023	Resumed bacteriological monitoring as required by state and federal regulations

This institution is an equal opportunity provider and employer.